DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: AH INC APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: TRIPLE OAKS LOT 8 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☑ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1	6%-4% LSS	0-3"	compacted clay	FARMED	FRENCH DRAIN 3-40" > Chroma 2				PS .2
		3-40"	heavy C, med, abk,	fr, s, p, scep					
		42-80"	cl, sap, abk/sbk	fr, ss, sp scep					
2	4% LSS	0-3"	comp, clay	FARMED	FRENCH DRAIN 3-40" > Chroma 2				PS .2
		3-36"	heavy C, med, abk	fr, s, p, scep					
		36-60"	cl sap, abk/sbk	fr, ss sp, scep					
3	4% LSC	0-3"	compacted clay	FARMED	FRENCH DRAIN > Chroma 2				PS .2
		3-40"	heavy C, med, abk	fr, s, p, scep					
		40-60"	cl sap, abk/sbk	fr, ss, sp, scep					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	CCA-1 PANEL	LP PANEL
Site LTAR	.2	.2

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK / BRADY FREEMAN
OTHER(S) PRESENT: MAX SPEAR JR.