DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: TRIPLE OAK LOT 6 APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: _____ PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed FRENCH DRAIN

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	4% L	0-3"	scl, wk, f	fr, ns, np, ap	mottles (rare) 4 few mottles	>48"			PS .25
		3-24"	cl, med, sbk, sbk	f, s, p, sl sp					
		24-48"	c, med, sbk/sbk	fr, s, p, sl sp					
2	4% L	0-3"	scl, wk, f	f, ns, np, ap	mottles (rare) 4 few mottles	>48"			PS .25
		3-24"	cl, med, sbk/sbk	f, s, p, sl sp					
		24-48"	c, med, sbk/sbk	fr, s, p, sl sp					
3	4% L	0-3	scl, wk, f	f, ns, np, ap	mottles (rare) 4 few mottles	>48"			PS .25
		3-8"	cl, med, sbk	f, s, p, sl sp					
		8-48"	c, med, sbk	fr, s, p, sl sp					
4	6% L	0-3"	scl, wk, fr	f, ns, np, ap					PS .2
		3-26"	cl, med, sbk,	fr, s, p, sl sp					
		26-48"	c, med, sbk	f, s, p, sl sp					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	GRAV 25-1,000	LPP PANEL
Site LTAR	.25	.2

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: _____