IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR LINDA MOORE DATE 12-23-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 64 east - T.L. on Old Mocksville Rd. - T.R. on Joe Deese Rd. 3/4 mi. on left - private drive - Mobile Home 250' off rd. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes (✓) No ( )
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )
Lot Area 2 acres.

Character & Porosity of Soil Clayey.
Percolation Rate 40 Gal./Sq. Ft.
Topography 2-4% fall
Depth to Water Table 4 ft
Rock or other impervious formations none observed.

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 5
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12
Water Supply: Individual (✓)
Public ( )

Installed by Paul Frye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Kelly Sheets R.S.

COMMENTS: Keep well at least 50' from S.T. system.

CERTIFICATE OF COMPLETION BY Steve Brown DATE 12-23-87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold