DENR/DEH

ON-SITE WASTEWATER SECTION

Sheet 1 of 1
PROPERTY ID #:
COUNTY:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Oakwood Homes
ADDRESS: Chestnut Grove Rd
PROPOSED FACILITY: 4BR PROPOSED DESIGN FLOW (.1949): 480
LOCATION OF SITE: Chestnut Grove
WATER SUPPLY: X Private • ✓ Public • Well • Spring • Other
EVALUATION METHOD: ✓ Auger Boring • Pit • Cut

APPLICATION DATE 6-14-13
DATE EVALUATED: 8-5-13
PROPERTY SIZE: .59 Ac
PROPERTY RECORDED: yes
TYPE OF WASTEWATER: X Sewage • Industrial Process • Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	LS 10	0-18	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		18-48	CL SBK	SS SP					
2	LS 10	0-19	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		19-44	CL SBK	SS SP					
3	LS 10	0-18	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		18-48	CL SBK	SS SP					
4	LS 10	0-18	C SBK	SS SP	n/a	48"	n/a	n/a	.3 PS
		18-48	CL SBK	SS SP					

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	III	IV
Site LTAR	.3	.3

OTHER FACTORS (.1946): none
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: James Stewart
OTHER(S) PRESENT: none

COMMENTS: