IREDELL COUNTY HEALTH DEPARTMENT

County Building — Phone 1164 — Statesville, N. C.

PERMIT TO INSTALL SEPTIC TANK

Permit No. _____ Permit Date _____ 194__

Owner Ralph + Sadie Murdock Address Rt. 5 - Statesville

Tenant _____ Address Rt. 4 - Statesville

Installed by G. W. Smith Address Rt. 2 Chestnut Grove Church

Location of Property _____

Kind of Tank Cinder Block Capacity 500 Length of trench 200 ft


NOTIFY HEALTH DEPARTMENT AT LEAST EIGHT HOURS BEFORE TANK IS TO BE INSPECTED

There must be at least 200 feet of tile in line, with cinder pit at end.

Final Inspection Oct. 17, 194 9 Approved (✓) Disapproved ( )

Remarks: straight drain line

First five feet of line from outlet should be of cast iron soil pipe.



James C. Brown

Sanitarian.

Sketch of tank and line showing distance from dwelling and well on subject property and on adjoining property.