DEPARTMENT OF ENVIRONMENT,
HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____ SHEET ____ OF ____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Natasha Brown
ADDRESS: _____
OWNER__ AGENT:__ PHONE: _____
APPLICATION DATE: _____ DATE EVALUATED _____
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: off Chestnut Grove Rd End of Pepperidge Rd
WATER SUPPLY: On-site Well____ Comm. Well____ Public____ Other_____ EVAL METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS / SLOPE(%)	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	MATRIX COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1		0 to 4	L	GR				.1942 Wetness Cond. N/A
	linear	4 to 42	C	SBK	lil			.1943 Depth/.1956 Sapr. N/A
		42 to 48	C	weak SBK	lil			.1944 Restrictive Hori. N/A
	690							.1948 Profile Class. PS
								Profile LTAR .35
2	linear	0 to 4"	L	GR				.1942 Wetness Cond. N/A
		4 to 42	C	SBK	lil			.1943 Depth/.1956 Sapr. N/A
	690	42 to 48	C	weak SBK	lil			.1944 Restrictive Hori. N/A
								.1948 Profile Class. PS
								Profile LTAR .35
3		0 to 6"	L	GR				.1942 Wetness Cond. N/A
	linear	6 to 42"	C	SBK	lil			.1943 Depth/.1956 Sapr. N/A
		42 to 48	C	weak SBK	lil			.1944 Restrictive Hori. N/A
	690							.1948 Profile Class. PS
								Profile LTAR .35
4								.1942 Wetness Cond. -
								.1943 Depth/.1956 Sapr. -
								.1944 Restrictive Hori. -
								.1948 Profile Class. -
								Profile LTAR -

AVAILABLE SPACE (.1945) Yes OTHER FACTORS (.1946) _____ SITE CLASSIFICATION (.1948) PS

SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .35

EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Natasha Brown

COMMENTS: _____