DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ____ of ____
PROPERTY ID #: ____
COUNTY: ____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

4/766-34-0337
104185

OWNER: DIANE MARSHALL APPLICANT: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____ PROPOSED DESIGN FLOW (.1949): ____ PROPERTY SIZE: ____
LOCATION OF SITE: ____ PROPERTY RECORDED: ____
WATER SUPPLY: ☒ Private ☐ Public ☐ Well ☐ Spring ☐ Other ____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	OTHER PROFILE FACTORS .1943 SOIL DEPTH	OTHER PROFILE FACTORS .1956 SAPRO CLASS	OTHER PROFILE FACTORS .1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	4% L	0-3"	scl, wk, gr	f ns np mpl		>48"			PS .3
		3-24"	c mod sbk	f ss sp scp					
		24-48"	loamy sap	f ss sp scp					
2	6% L CV	0-3"	scl wk gr	f ns np mpl		>48"			PS. .3
		3-12"	c mod sbk	f ss sp scp					
		12-48"	loamy sap	f ss sp scp					
3	4% L		SAME AS HOLE 1						
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	CONV GRAV	Same
System Type(s)	YES	YES
Site LTAR	.3	.3

OTHER FACTORS (.1946): ____
SITE CLASSIFICATION (.1948): ____
EVALUATED BY: L. Cook
OTHER(S) PRESENT: ____