Permit #177944
Jerry James

Rt 1 Box 149 Stat

I

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jerry James DATE 6-24-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION old mocksville Rd TR on Chestnut Grove Rd 1st house on left past Allen creek Rd S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other repair

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil Clayey
Percolation Rate 4
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations None

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 12"
Water Supply: Individual (✓)
Public ( )

Installed by Effie Yountz Sons

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P.C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P.C. Moore DATE 6-24-87

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MI Location of the proposed 13'X13' Bathroom Addition , REGULATIONS.
Permit is VOID if any unauthori addition does not appear to impact the existing on-site oiled in making
Improvements Permit. septic system.**NOTE:

Health Dept. Copy

Justin Henderson REHS
Date: 4-25-13
ICHD-Environmental Health Division

's Copy: Gold