DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY RECORDED: _____
COUNTY: _____

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: Kenneth N. James OWNER: __ AGENT: __ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ___ Pit ___ Cut ___

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1945 CLASS OF HORIZ | 1945/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | Linear 590 | 0 to 12 | L GR | | PS | PS | PS | PS | .3 |
| | | 12 to 30 | C SBK | SEAP Fi | | | | | |
| | | 30 to 48 | CL WSBK | SEAP Fi+Fr | | | | | |
| 2 | Linear 590 | 0 to 8 | L GR | | PS | PS | PS | PS | .33 |
| | | 8 to 34 | C SBK | SEAP Fi+Fr | | | | | |
| | | 34 to 42 | CL WSBK | SEAP Fi+Fr | | | | | |
| | | 42 to 48 | SCL WSBK | NEAP Fr | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |

AVAILABLE SPACE (.1945) Y/N SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Kenneth James
COMMENTS: _____

001385