DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: ___
104885
4766-72-8834

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: LENNY WATTS APPLICANT: ___
ADDRESS: ___ APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: ___ PROPOSED DESIGN FLOW (.1949): ___ PROPERTY SIZE: ___
LOCATION OF SITE: 7 SPRINGS LOT 81 PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

UP ASIDE DRAINAGE WAY - 7 NEED FD.

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	2% L to CC	0-8"	scl w sr	f nsp nep	32-45" yellowish mottles				PS .25
		8-32"	c med sbk	f ss sp sep					
		32-45"	c med sbk	f ns p sep					
2	8% L to CC	0-8"	scl w sr	f ns p nep	32-46" yellowish mottles; 46-48" crumb 2 → > USAT 46"				PS .25
		8-32"	c med sbk	f ss p sep					
		32-46"	c med sbk	f s p sep					
		46-48"	c med sbk	f s p sep					
3	2% L to CC	0-6"	scl w sr	f ns p nep	12-24" yellowish mottles crumb 2 at 24"			FRENCH DRAIN SHOULD TAKE CARE OF IT	PS .2
		6-18"	c med sbk	f ss sp sep					
		18-48"	c med sbk	f s p sep					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	YES	YES
System Type(s)	EP CONV. A-1	PUMP / SHALLOW CONV. / 2 SYSTEMS
Site LTAR	.25	.2 BASIC .3 FRENCH PUMP SOIL FOLLOWER

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: CICCOLI
OTHER(S) PRESENT: K WATT / DAVID YOUNG