IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR W B Whitley DATE 5-3-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. Left on Rd # 258 (old Mocksville Rd) To Jerusalem Church TR on Rd # 3169 then left on Rd # 3168 - TL on 1st dirt road - House on Rt. S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Lot Area Acreage

Character & Porosity of Soil Red Clay


Percolation Rate Fast

Topography Slope to back

Depth to Water Table _____

Rock or other impervious formations None

House Started Prior To Oct. 1 - 1973



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines _____

Water Supply: Individual (✓)
Public ( )

Installed by Hubert Looney

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 5-3-74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold