34742

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

10168

OWNER OR CONTRACTOR JA Bynum DATE 32390 PERMIT NO.

PHONE: Business Home

LOCATION 21N to Dunlap gate L Creekview 3rd Lot on Right 20th Creekview Drive S. R. No.

SUBDIVISION NAME Dunlap gate LOT NO. 37 SECTION OR BLOCK NO.

House (✓) Mobile Home ( ) Business ( ) Other

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area .95

Character & Porosity of Soil Clay


Percolation Rate 61

Topography Slope

Depth to Water Table 24

Rock or other impervious formations None

_____ Basement with Plumbing ___✓___ Basement without Plumbing _____ No Basement



Plot of System

Size of Tank 1250 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 300 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ( )

Public (✓)

Installed by John Miner

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R R Pierce

COMMENTS:

CERTIFICATE OF COMPLETION BY _____ DATE 3/25/90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold