HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Acorn Development Co. OWNER: _____ AGENT: _____ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-12-93
PROPOSED FACILITY: Single Family Dwelling
PROPERTY SIZE: 100' x 300'
LOCATION OF SITE: Dunlap Gate Rd Fairview Lot 2
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other ✓ EVAL METHOD: Auger Boring ___ Pit ✓ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Linear 2 to 4%	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 42	C	ABL	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2		0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 42	C	ABL	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) yes SITE CLASSIFICATION (.1945): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE Conv Gravity
EVALUATED BY: J. C. Moore OTHER(S) PRESENT: Tom White
COMMENTS: _____

DRAFT