IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Jeff Holton DATE 4/16/79 PERMIT NO. _____

PHONE Business _____ Home _____

LOCATION Old 21, T.R. on Rd 2442 (Cristland Grove Rd), T.L. on 21 ~, last Lot on left behind brick home S. R. No. _____


SUBDIVISION NAME _____ LOT NO _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil Gravel & Clay + gravelly clay loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate 60 MPI
Auto. Wash Machine	Yes (✓)	No ( )	Topography Rolling Hills
Site Suitable	Yes (✓)	No ( )	Depth to Water Table 10'+
			Rock or other impervious formations some found

Lot Area 2 acres



Plot of System

Size of Tank 1000 Gals.
Nitrification Field
No. of Lines 2
Sq. Ft. 250 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by _____

IMPROVEMENTS PERMIT BY J. L. Moore

COMMENTS _____

CERTIFICATE OF COMPLETION BY Gordon E. Lowe DATE 4/16/79

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Health Dept. Copy White Inspection Dept. Copy Yellow Sanitarian's Copy Pink Owner's Copy Gold