IMPROVEMENT PERMIT / AUTHORIZATION TO CONSTRUCT / OPERATION PERMIT / EXISTING SYSTEM

DEPARTMENT Statesville Office (704) 878-5305 Mooresville Office (704) 660-3625 PERMIT # 203289

APPLICANT: Trever Cardea APPLICANT ADDRESS: 103 Green Meadows Ln Statesville NC 28625

SITE ADDRESS: 770 Church Lake Rd Statesville NC 28625 PHONE: 704-682-3476 ALT. PHONE: N/A

SITE DIRECTIONS: Old Mocksville Rd to Church Lake Rd 1/2 mile on left PIN # 4767586325

SUBDIVISION: Rush Limited Partnership SECTION: N/A LOT # 1 LOT AREA: 2.547 ac

Septic Tank 1000 (gal) STB Date

Pump Tank (gal) PT Date

Pump Make Model Serial #

Nitrification Fields 1 # Lines 4 Linear Ft: 160

Trench Width 36" Max. Trench Bottom Depth 36" Gravel Depth N/A

☒ New System ☐ Repair ☐ Expansion System Type: I II (III) IV V VI

System Description: 25% Reduction

Repair System Description: 25% Reduction

Maintenance Agreement Required: ☐ YES ☒ NO

☒ GRAVITY ☐ PRESSURE

DESIGN FLOW: 200 L.T.A.R.: 0.3

☐ Residence No. Bedrooms 1 Bathroom

☐ Business No. Persons

☐ Other No. Employees

☒ Slab ☐ Crawl Space

☐ Basement w/plumbing

Water Supply: ☐ Private ☒ Public ☐ Community

☐ Basement w/o plumbing

Comments / Conditions: Install 25% Reduction on contour with serial distribution. Owner request larger system for Barn Bathroom.

INITIAL SITE SKETCH

AS-BUILT SKETCH

Revoked

(500') P/L

DRIVE

Church Lake Rd (21' P/L)

50'

BARN

72'

32'

33'

25% Repair Area

95'

70'

(476') P/L

1" = 60'

Permit can be suspended or revoked if any false information is supplied toward securing the permit / any unauthorized changes are made to the site / any unauthorized changes are made in the installation of the system. CONTACT A LOCATOR SERVICE PRIOR TO ANY EXCAVATION

☐ IMPROVEMENT PERMIT with plat valid without expiration.

☒ IMPROVEMENT PERMIT with site plan valid for 60 mos.

☒ AUTHORIZATION TO CONSTRUCT valid for period equal to IMPROVEMENT PERMIT--not to exceed 60 mo.

Owner / Applicant Signature: Cardea

IMPROVEMENT PERMIT by: Date: 06/20/14

AUTHORIZATION TO CONSTRUCT by: Date: 06/11/14

Installed by:

OPERATION PERMIT by: Date: 06/11/14

Existing System Inspected by: Date:

Health Dept. Copy - WHITE Applicant (Final Approval) - YELLOW Applicant (Conditional Approval) - PINK