IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Franklin Real DATE 12 Apr 77 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION old Mocksville Rd & Rd 2156 - to appx. 1 mile to entrance of Church's Lake. Home back off Rd # 2156 appx ¼ mile S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay Loam
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	none
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	G-rolling
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	wl
			Rock or other impervious formations	wl

Lot Area 3 acres



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 625 Linear Ft. 250
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY _____

COMMENTS: Dug Pit 9-13-76 Hoke Septic Tank Co.

CERTIFICATE OF COMPLETION BY W. M. Howard DATE 12 Apr 77

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold