IREDELL COUNTY HEALTH DEPARTMENT

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

15566

OWNER OR CONTRACTOR W. B. NORRIS, JR DATE 1/15/93 PERMIT NO. 13J-A-7

PHONE: Business _____ Home _____

LOCATION I-77 N, TR TOMLIN MILL ROAD, 1ST HOUSE ON (L) PAST RASH ROAD S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

S/W

House ☐ Mobile Home ☑ Business ☐ Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes ☐ No ☑

Auto. Dishwasher Yes ☑ No ☐

Auto. Wash. Machine Yes ☑ No ☐

Lot Area 1.03 ACRES

Soil Characteristics PS


Application Rate 0.40 GPD / FT²

Topography 2-2% LINEAR

Depth to Water Table 54"

Rock or other impervious formations NONE

_____ Basement with Plumbing _____ Basement without Plumbing ⊗ No Basement WELL ✓ Crawl Space



Plot of System (Not to Scale)

Size of Tank 1000 Gals.

Nitrification Field:

No. of Lines 3

Sq. Ft. 900 Linear Ft. 300

Depth of Stone in Lines 12"

Water Supply: Individual ☑ WELL

Public ☐

Installed by _____

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY STEVE HEDRICK

COMMENTS REPAIR AREA IS 100% CONVENTIONAL, GRAVITY-FED

CERTIFICATE OF COMPLETION BY STEVE HEDRICK DATE 1/15/93

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold