DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: ____
COUNTY: IREDELL
4769 74 9586

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: JEFF BILLINGS APPLICANT: SAME
ADDRESS: 142 TABOR ROAD APPLICATION DATE: _____ DATE EVALUATED: 3-29-99
PROPOSED FACILITY: 3BR HOUSE PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: 2.2 ACRES
LOCATION OF SITE: US 21 N, TL TABOR RD, 3RD LOT ON RIGHT PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☑ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☑ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☐ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	L	0-48	SBK / SC	FR SEXP					PS 0.4
2	L	0-48	SBK / SC	FR SEXP					PS 0.4
3	H	0-26	SBK / C	FI/P/ SEXP					PS 0.4
		26-48	SBK / SC	FR / SEXP					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	S	S
System Type(s)	II	II
Site LTAR	0.4	0.4

OTHER FACTORS (.1946): NONE
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: S. HENDRICK
OTHER(S) PRESENT: JEFF BILLINGS