DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #: ___
COUNTY: Fisher

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM 546-7605

OWNER: Anita Bunt APPLICANT: Anita Bunt
ADDRESS: Talor Rd Torrence Landing APPLICATION DATE: ___ DATE EVALUATED: ___
PROPOSED FACILITY: 3BR/2 mobile PROPOSED DESIGN FLOW (.1949): 360 gpd PROPERTY SIZE: 10 acres
LOCATION OF SITE: w/ Basement + Plumbing PROPERTY RECORDED: ___
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other ___
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) .1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	4% Linear	0-6	SL gr fr						PS .3
		6-36	SCL wsbk fr	SS SP SPl	24"				
		36-48	SCL msbk fi	S P	6YR 4/6 M				
2	4% Linear	0-8	SL gr fr	NS MP MPl					PS .3
		8-24	SCL msbk fr	SS SP SPl	30"				
		24-48	SCL msbk fi	SP SPl					
3	6% Linear	0-4	SL gr fr	NS MP MPl					PS .3
		4-24	SCL wsbk fr	SS SP SPl					
		24-48	SCL msbk fi	SP SPl					
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	
System Type(s)	Ground Abs	Elev Abs
Site LTAR	.3	.3

OTHER FACTORS (.1946): ___
SITE CLASSIFICATION (.1948): ___
EVALUATED BY: [illegible]
OTHER(S) PRESENT: ___