IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

13000
OWNER OR CONTRACTOR ARTHUR R. DISHMAN DATE 6/18/91 PERMIT NO. 12H-A-143

PHONE: Business _____ Home _____

LOCATION US 21 N, ON L PAST TABOR ROAD, LAST LOT BEFORE DUTCHMAN CREEK. S. R. No. _____

SUBDIVISION NAME TWENTY-ONE ACRES LOT NO. 14 SECTION OR BLOCK NO. _____


House ( ) Mobile Home (L) ~~DBL WIDE~~ Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2
Garbage Disposal Unit Yes ( ) No (L)
Auto. Dishwasher Yes (L) No ( )
Auto. Wash. Machine Yes (L) No ( )
Site Suitable Yes (L) No ( )
Lot Area 3.13 AC

Character & Porosity of Soil PS
Percolation Rate 4 GPA / FT²
Topography 4-6% LS
Depth to Water Table >4'
Rock or other impervious formations NONE

_____ Basement with Plumbing F Basement without Plumbing L No Basement

ACP 5/14/91



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ( )
Public (L)

Installed by KEITH SPEECE

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY STEVE HEARICK

COMMENTS: _____

CERTIFICATE OF COMPLETION BY STEVE HEARICK DATE 6/18/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold