12303

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Colin Richards DATE 4/11/91 PERMIT NO. 4W-A-44

PHONE: Business _____ Home _____

LOCATION 115N, Rt on Shinville, Go 5.7 miles to site on Rt in field

_____ S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 5 acres

Character & Porosity of Soil clayey


Percolation Rate 0-3 spd/ft²

Topography 2-5% slope

Depth to Water Table 4' 6"

Rock or other impervious formations See imp. permit

(✓) Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Plot of System

Size of Tank 1250 per owner Gals.

Nitrification Field:

No. of Lines 2

Sq. Ft. 810 Linear Ft. 270

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Dennis Gallihar

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY Wesley Sparks, RS

Shinville Road

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____ DATE 4/11/91

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

IREDELL COUNTY HEALTH DEPARTMENT

12303

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Colin Richards DATE 1/15/91 PERMIT NO. 4-J-A-44

PHONE: Business _____ Home 664-7860

LOCATION 115 N, TR ON SHIMNEVILLE RD, 5.7 miles to property on R in open field area

S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)
Auto. Dishwasher	Yes (✓)	No ( )
Auto. Wash. Machine	Yes (✓)	No ( )
Site Suitable	Yes (✓)	No ( )

Character & Porosity of Soil Clayey

Percolation Rate 3


Topography 2-5% rolling

Depth to Water Table 4'

Rock or other impervious formations slight shaley in one hole

Lot Area 5 AC.

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 810 Linear Ft. 270
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: X Colin P Nelson

IMPROVEMENTS PERMIT BY Wesley Sparks RS / David K Hinson, EHC

COMMENTS: Septic tank set so lines can follow contour toward Shimnville Rd. Lines must be 15' minimum away from pool area. D/W must be 40' inside the side property boundary. Trenches no deeper than 36" to trench bottom.

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold