DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

SHEET ____ OF ____
PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

# SOIL/SITE EVALUATION
## FOR
## ON-SITE WASTEWATER SYSTEM

APPLICANT: HAROLD FREEZE OWNER: ✓ AGENT: ___ PHONE: N/A
ADDRESS: Rt 2 Box 323 APPLICATION DATE: 7/24/93 DATE EVALUATED: 7/26/93
CLEVELAND, NC. PROPOSED FACILITY: 5BD. 3BA
PROPERTY SIZE: ____
LOCATION OF SITE: TRIPLETT RD. X CREEK .75 MILE ON (L) WHITE FRAME
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

| PROFILE # | .1940 LANDSCP POS. (%) | HORIZON DEPTH (IN.) | .1941 STRUCTURE/TEXTURE | .1941 MINERALOGY/ CONSISTENCE | .1942 WETNESS COND. | .1944 RESTRICT HORIZONS | .1948 CLASS OF HORIZ | 1943/ 1956 SAPRLT CLASS. | HORIZON LTAR |
|---|---|---|---|---|---|---|---|---|---|
| 1 | 2% | 0-6 | 0 sl | 1:1 | ~~wpo~~ - wpo | | | | |
| | | 7-21 | 1 sl | 1:1 | ~~ws~~ - wpo | | | | |
| | | 22-30 | 2 sbk sel | 1:1 | ws - wp | N/A | P | P | |
| | | 31-39 | 3 vfgr sbk sel | 1:1 | ws - wps | MIX | P | P | |
| | | 40-44 | 2 sbk sel | 1:1 | wss - wps | SAP. | P | 11 NS | .3 |
| 2 | | | | | | | | | |
| 3 | | | | | | | | | |
| 4 | | | | | | | | | |
| 5 | | | | | | | | | |

AVAILABLE SPACE (.1945) 5 SITE CLASSIFICATION (.1948): P SITE LONG-TERM ACCEPTANCE RATE: .25 - .3
EVALUATED BY: Sparks OTHER(S) PRESENT: Harold Freeze
COMMENTS: ____