DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Lonnie Holmes OWNER__ AGENT__ PHONE: _____
ADDRESS: _____ APPLICATION DATE _____ DATE EVALUATED: 5-26-95
_____ PROPOSED FACILITY: _____
_____ PROPERTY SIZE: _____
LOCATION OF SITE: _____
WATER SUPPLY: On-Site Well____ Comm. Well__ Public___ Other_____ EVAL. METHOD: Auger Boring__ Pit__ Cut___

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	(a)(2) STRUCTURE	(a)(3) MINEROLOGY	
1	Linear 10 to 12%	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 48	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Linear 10%	0 to 4	L	GR		.1942 WETNESS CONDITION - N/A
		4 to 48	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	Linear 10%	0 to 6	L	GR		.1942 WETNESS CONDITION - N/A
		6 to 80	C	ABK	1:1	.1943/.1956 SAPROLITE - N/A
		6+ to 48	C/L	weak ABK	1:1	.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
4	Linear 10%	0 to 8	L	GR		.1942 WETNESS CONDITION - Chroma 2
		8 to 24	C	ABK	mixed	.1943/.1956 SAPROLITE - N/A
		24 to 36	C	ABK	2:1	.1944 RESTRICTIVE HORIZON - mottling
						.1948 PROFILE CLASSIFICATION - U
						PROFILE LTAR - .1
5	Linear 6%	0 to 8	L	GR		.1942 WETNESS CONDITION - Chroma 2
		8 to 24	C	ABK	mixed	.1943/.1956 SAPROLITE - N/A
		24 to 36	C	ABK	2:1	.1944 RESTRICTIVE HORIZON - mottling
						.1948 PROFILE CLASSIFICATION - U
						PROFILE LTAR - .1

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE Conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT _____ Lonnie Holmes
COMMENTS: _____

DRAFT