HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Robert Wolff OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Ridge 6%	0 to 2	L	GR		.1942 WETNES CONDITION - N/A
		2 to 29	C	ABK	li	.1943/.1956 SAPROLITE - N/A
		29-38	C	weak ABK	li	.1944 RESTRICTIVE HORIZON - N/A
		38 to 48		Transition		.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
2	Ridge 6%	0 to 2	L	GR		.1942 WETNES CONDITION - N/A
		2 to 36	C	ABK	li	.1943/.1956 SAPROLITE - N/A
		36 to 48		Transition		.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .3
3	Linear 4%	0 to 2	L	GR		.1942 WETNESS CONDITION - Chroma 3
		2 to 36	C	ABK	li	.1943/.1956 SAPROLITE - N/A
		36 to 48		Transition		.1944 RESTRICTIVE HORIZON - N/A
						.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .25
4	Linear 4%	Fill material				.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION - unsuitable
						PROFILE LTAR -
5	Linear 4%	Fill material				.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION - unsuitable
						PROFILE LTAR -

AVAILABLE SPACE (.1945) Panels SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: L.C. Moore OTHER(S) PRESENT: Robert Wolff Jim Barkley
COMMENTS:

DRAFT