ON-SITE WASTEWATER SECTION COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Harold Gulledge OWNER AGENT PHONE:
ADDRESS: APPLICATION DATE DATE EVALUATED:
PROPOSED FACILITY
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS / SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	Linear 690	0 to 12"	L	Gr		.1942 WETNESS CONDITION	N/A
		12 to 28	CL	Gr	1:1	.1943/.1956 SAPROLITE	N/A
		28 to 48	C	SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
						.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
2	Linear 690	0 to 4	L	Gr		.1942 WETNESS CONDITION	N/A
		4 to 29	C	SBK	1:1	.1943/.1956 SAPROLITE	N/A
		29 to 36	C	weak SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		36 to 48		Transition		.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
3	Linear 670	0 to 12	L	Gr		.1942 WETNESS CONDITION	N/A
		12 to 24	CL	Gr	1:1	.1943/.1956 SAPROLITE	N/A
		24 to 42	C	SBK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		42 to 48	C	weak SBK	1:1	.1945 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.35
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1945 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1945 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945): Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946): SYSTEM TYPE: Conv Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: Harold Gulledge
COMMENTS:

DRAF