HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: James Carr OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: LOT 72 Willow Ridge
WATER SUPPLY: On-Site Well ✓ Comm. Well ___ Public ___ Other ___ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	Ridge 2 to 4%	0 to 4"	L	GR		.1942 WETNES CONDITION - N/A
		4 to 18	CL	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		18 to 36	C	SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	Transition			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
2	Linear 6 to 8%	0 to 4	L	GR	1:1	.1942 WETNES CONDITION - N/A
		4 to 24	CL	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		24 to 36	C	SBK	1:1	.1944 RESTRICTIVE HORIZON - N/A
		36 to 48	Transition			.1948 PROFILE CLASSIFICATION - PS
						PROFILE LTAR - .35
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1948 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) YES SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .35
OTHER FACTORS(.1946) ____ SYSTEM TYPE ____
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: ____
COMMENTS: ____

DRAFT