4771531064

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Franklin Beaver DATE 7/15/87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 801 N. TL 2362 (Triplett Rd.) TR 1001 (Oswalt Amity Rd) ~ 3/4 mile TR just befor "Beavers Siglo". S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____


No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Character & Porosity of Soil clay
Percolation Rate ~.4
Topography 4-6%
Depth to Water Table 4' +
Rock or other impervious formations none observed

Lot Area ~1 Ac

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"
Water Supply: Individual ✓
Public ( )

Installed by Rowan Septic Tank George Kirkpatrick

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY DRH, R.S.

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Andrew C. Pierce, DRHanson, RS DATE 7/15/87

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold

0885

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR James Franklin Beaver Jr. DATE 6-29-87 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 801 N. TR 2362 (Triplett Rd.) TR 1001 (Amity Rd.) ~3/4 mile TR "Beaver Sign" at end on Rt (300'+ off S. R. No. 2)

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate	~40	
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	4-6%	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	4'	
			Rock or other impervious formations	none obs.	

Lot Area 1 AC

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 900 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )
well already down

Installed by _____

I understand and agree to install septic tank system as specified on this Improvements Permit.

X Signed: James Franklin Beaver Jr.

IMPROVEMENTS PERMIT BY [illegible]

COMMENTS: Modify (shape) area drainfield is to be installed so lines can be at a consistent depth & follow contour. Use drop boxes to distribute

CERTIFICATE OF COMPLETION BY _____ DATE _____

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold