## IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System - G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR G. B Beaver DATE 6-2-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Amity Hill Rd #1001 on left before Rowan County line off Rd. (in Pasture) S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

| | | | | | |
|---|---|---|---|---|---|
| Garbage Disposal Unit | Yes ( ) | No (✓) | Character & Porosity of Soil | CMB2 |
| Auto. Dishwasher | Yes ( ) | No (✓) | Percolation Rate | Sandy Mud |
| Auto. Wash. Machine | Yes (✓) | No ( ) | Topography | 2-6% Slope |
| Site Suitable | Yes (✓) | No ( ) | Depth to Water Table | Unk |
| | | | Rock or other impervious formations | None |

Lot Area _____




Plot of System

Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed William Culbertson

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 6/2/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold