IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Steve W. Beaver DATE 6-2-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Amity Hill Rd # 1001 at Rowan County Line

S. R. No. 1001


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____ Prop. Santana

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	C M B z
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Sur. Mod
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 - 6% Slope
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	over
			Rock or other impervious formations	none

Lot Area _____



Size of Tank 1000 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by William Cathcart

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Steve W. Beaver DATE 6/2/78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold