DEPARTMENT OF ENVIRONMENT, HEALTH & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

DRAFT

PROPERTY I.D.#: _____
DATE: _____
COUNTY: _____

SOIL SITE EVALUATION FOR ON-SITE WASTEWATER SYSTEM

APPLICANT: Ed Brown OWNER ___ AGENT: ___ PHONE: _____
ADDRESS: _____ APPLICATION DATE _____ DATE EVALUATED _____
PROPOSED FACILITY _____
PROPERTY SIZE _____
LOCATION OF SITE: Lot 8 Amity Hill Est.
WATER SUPPLY: On-site Well ___ Shared Well ___ Public ___ Other ___ EVAL METHOD: Auger Boring ___ Pit ___ Cut ___

PROFILE #	1940 LANDSCP POS./ SLOPE(%)	HORIZON DEPTH (IN.)	1941 TEXTURE	1941 STRUCTURE	1941 MINERALOGY	MAJOR COLOR	MOTTLE COLOR	OTHER PROFILE FACTORS
1	Linear H90	0to2	L	GR				1942 Wetness Cond. N/A
		2to24	C	SBK	1:1			1943 Depth/ 1956 Sapr. N/A
		24to36	CL	weak SBK	1:1			1944 Restrictive Hori. N/A
		36to48	Transition					1948 Profile Class PS
								Profile LTAR .35
2	Linear H90	0to2	L	GR				1942 Wetness Cond. N/A
		2to24	C	SBK	1:1			1943 Depth/ 1956 Sapr. N/A
		24to30	CL	weak SBK	1:1			1944 Restrictive Hori. N/A
		30to48	Transition					1948 Profile Class PS
								Profile LTAR .35
3								1942 Wetness Cond.
								1943 Depth/ 1956 Sapr.
								1944 Restrictive Hori.
								1948 Profile Class.
								Profile LTAR
4								1942 Wetness Cond.
								1943 Depth/ 1956 Sapr.
								1944 Restrictive Hori.
								1948 Profile Class.
								Profile LTAR

AVAILABLE SPACE (1945) yes OTHER FACTORS (1946) _____ SITE CLASSIFICATION (1948) PS
SYSTEM TYPE Conv. Gravity LONG-TERM ACCEPTANCE RATE(S) .35
EVALUATED BY: J. C. Moore OTHER(S) PRESENT: Ed Brown
COMMENTS: _____