IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Glenn Faust DATE 1-12-76 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Highway 70 E. to Elmwood – TR on Rd # 1362 Mobile home across from Grange on left


SUBDIVISION NAME _____ S. R. No. 2362

LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other Septic Tank System Designed for 2 Mobile Homes

No. Bedrooms 4 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	Low Range
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope to Level
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	25'
Lot Area Adequate			Rock or other impervious formations	None



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 3 – End Feed

Sq. Ft. 1250 Linear Ft. 500

Depth of Stone in Lines 10"

Water Supply: Individual (✓)

Public ( )

Installed by Hardin Looky

IMPROVEMENTS PERMIT BY _____

COMMENTS Installed during cold + wet conditions

CERTIFICATE OF COMPLETION BY Glenn Faust Jr. DATE 1/12/76

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold