DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of ___
PROPERTY ID #:
COUNTY: Iredell

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: Kimberly Rowe APPLICANT:
ADDRESS: 156 Bluegill Lane STATESville APPLICATION DATE: 4-4-00 DATE EVALUATED: 5-15-2000
PROPOSED FACILITY: 3Bdrm DW PROPOSED DESIGN FLOW (.1949): 360 PROPERTY SIZE: .55
LOCATION OF SITE: Hwy 70 E (R) Tippett (R) Brown Farm Lot 12 on left 2nd PROPERTY RECORDED:
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFILE CLASS & LTAR
1	L 3-4%	0-8	SAB	CL FR					PS .3
		8-52	SAB	C Mica FR-FI	SS SEP				
2	L 3-4%	0-8	SAB	CL FR					PS .3
		8-36	SAB	C Mica FR	SS SEP				
		36-52	SAB	C Mica FR					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	↘	↘
System Type(s)	Conv Gravity	Sim
Site LTAR	.3	.3

OTHER FACTORS (.1946): PS
SITE CLASSIFICATION (.1948):
EVALUATED BY
OTHER(S) PRESENT: