DEPARTMENT OF ENVIRONMENT,
HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: myrtle Keller OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:

LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 290	0 to 15	L G VF	NEAP FR	chroma 2 at 36"	E. clay 24 to 36	PS for ultra shallow	PS	.2
		15 to 24	C ABK	SEAP Fi					
		24 to 48	C ABK	SEAP VFi					
2	linear 290		same						.2
3	linear 290		same						.2
4									
5									

AVAILABLE SPACE (.1945): SITE CLASSIFICATION (.1948): PS for SITE LONG-TERM ACCEPTANCE RATE: .2
EVALUATED BY: R. C. moore OTHER(S) PRESENT: ultra shallow
COMMENTS: