EPARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH

SHEET____OF_____
PROPERTY I.D.#:_____
PROPERTY RECORDED:_____
COUNTY:_____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PLICANT: Acorn Bldg Co. OWNER:_AGENT:__ PHONE:_____
DDRESS:_____APPLICATION DATE:_____DATE EVALUATED:_____
PROPOSED FACILITY:_____
PROPERTY SIZE:_____
CATION OF SITE: lot 17 crestfield
ATER SUPPLY: On-Site Well____Comm. Well___Public___Other_____EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	.1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	linear 6%	0 to 48	C SbK	SEAP SS SP	PS	PS	PS	N/A	.3
2	linear 6%	0 to 48	C SbK	SEAP SS SP	PS	PS	PS	N/A	.3
3									
4									
5									

AILABLE SPACE (.1945) Y/N SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
ALUATED BY: J.E. moore OTHER(S) PRESENT: michael white
OMMENTS:_____

A03396