HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: ____
PROPERTY RECORDED: ____
COUNTY: ____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Carrie Upright OWNER: AGENT: PHONE: ____
ADDRESS: ____ APPLICATION DATE: ____ DATE EVALUATED: ____
PROPOSED FACILITY: ____
PROPERTY SIZE: ____
LOCATION OF SITE: ____
WATER SUPPLY: On-Site Well____ Comm. Well___ Public___ Other____ EVAL. METHOD: Auger Boring___ Pit___ Cut___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY		
1	linear 6%	0 to 12	L	GR		.1942 WETNESS CONDITION	N/A
		12 to 30	C	ABK	1:1	.1943/.1956 SAPROLITE	N/A
		30 to 36	C	weak ABK	1:1	.1944 RESTRICTIVE HORIZON	N/A
		36 to 48	C	weak ABK	mixed	.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.25
2	linear 6%	0 to 12	L	GR		.1942 WETNESS CONDITION	N/A
		12 to 48	C	ABK	1:1	.1943/.1956 SAPROLITE	N/A
						.1944 RESTRICTIVE HORIZON	N/A
						.1948 PROFILE CLASSIFICATION	PS
						PROFILE LTAR	.3
3						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
4						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	
5						.1942 WETNESS CONDITION	
						.1943/.1956 SAPROLITE	
						.1944 RESTRICTIVE HORIZON	
						.1948 PROFILE CLASSIFICATION	
						PROFILE LTAR	

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .28
OTHER FACTORS(.1946) ____ SYSTEM TYPE conv. Gravity
EVALUATED BY: J.C. Moore OTHER(S) PRESENT: ~~Carrie~~ Frank upright
COMMENTS: ____

DRAFT

0026146