DEPARTMENT OF ENVIRONMENT, HEALTH, AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

Sheet ___ of _
PROPERTY ID #: _____
COUNTY: _____

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

OWNER: _____ APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 10-04-02
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): 480 GPD PROPERTY SIZE: _____
LOCATION OF SITE: LOT #21 BROWN FARMS PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☐ Public ☒ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☒ Auger Boring ☐ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) .1941 STRUCTURE/ TEXTURE	.1941 CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL CLASS & LTAR
1		0-18	W, F, sbk, C	Fr, S, P, sexP	Chrm 2 Motls @ 18"-48"				0.30 PS
		18-48	W, F, sbk, C	Fr, S, P, sexP					
2		0-20	W, F, sbk, C	Fr, S, P, sexP	Chrm 2 @ 15"				0.30 PS
		20-40	W, F, sbk, SC	Fr, SS, P, sexP	Chrm 2 @ 20"				
		40-48	W, F, sbk, C	Fr, S, P, sexP					
3									
4									

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	PS	PS
System Type(s)	PS	PS
Site LTAR	0.30	0.30

OTHER FACTORS (.1946): Needs French Drain
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: Patrick Mitchell
OTHER(S) PRESENT: _____