IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

Sherrill Faw
OWNER OR CONTRACTOR Thelma Mills DATE 6-23-83 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70 E approx 6mi Past Hezikiah Rd
Then Property 400' on R

SUBDIVISION NAME _____ S. R. No. _____

LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 5 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Clay (Class VI-A)
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	4 gal/sq ft/day
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	2 to 6%
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	10' +
			Rock or other impervious formations	none

Lot Area 1 acre

✓ Basement with Plumbing _____ Basement without Plumbing _____ No Basement



Plot of System ⊗ Proposed well location

Size of Tank 1250 Gals.

Nitrification Field:
No. of Lines 4
Sq. Ft. 1500 Linear Ft. 500
Depth of Stone in Lines 12 11

Water Supply: Individual (✓)
Public ( )

Installed by sterling church
Sherrill Faw Co.

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY L. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY _____

EXISTING SYSTEM CHECKED BY: L. C. Moore DATE 6-23-83

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS. DATE _____

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold