13311.

IREDELL COUNTY HEALTH DEPARTMENT 40974

IMPROVEMENT PERMIT AND CERTIFICATE OF COMPLETION / OPERATIONS PERMIT

OWNER OR CONTRACTOR Charles Welling DATE 4-15-92 PERMIT NO. SJA25

PHONE: Business _____ Home _____

LOCATION 70 E on Rt. at Triplett Rd

S.R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ☐ Mobile Home ☐ Business ☐ Other Conv. Store 1 bath 1 Fixture

No. Bedrooms _____ No. Bathrooms _____

Garbage Disposal Unit Yes ☐ No ☐

Auto. Dishwasher Yes ☐ No ☐

Auto. Wash. Machine Yes ☐ No ☐

Lot Area _____

Soil Characteristics Clayey


Application Rate .2 gal/sq. ft/day

Topography 2 to 6%

Depth to Water Table 10'+

Rock or other impervious formations none

_____ Basement with Plumbing 3'x70' Basement without Plumbing _____ No Basement _____ Crawl Space



Plot of System (Not to Scale)

Size of Tank Existing 1000 Gals.

Nitrification Field:

No. of Lines 6

Sq. Ft. 1260 Linear Ft. 420

Depth of Stone in Lines 12"

Water Supply: Individual ☑

Public ☐

Installed by James Hutler

I understand and agree to install a septic tank system as specified on this Improvement Permit.

Signed: _____

(IMPROVEMENT PERMIT IS VALID FOR 60 MONTHS FROM DATE OF ISSUE.)

IMPROVEMENT PERMIT BY L. C. moore

COMMENTS _____

CERTIFICATE OF COMPLETION BY L. C. moore DATE 4-15-92

EXISTING SYSTEM CHECKED BY _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS

Permit is VOID if any unauthorized changes are made in installation of system, and/or if any unapproved changes are made to the site, and/or if any false information is supplied toward securing Improvement Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold