IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Knott Oil Co. DATE 8-20-74 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Highway #70 East to near Elmwood S/S. #70 and Amity Hill Road #2362 S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business (✓) Other _____


No. Bedrooms 3 No. Bathrooms 4

Garbage Disposal Unit	Yes ( )	No (✓)	
Auto. Dishwasher	Yes (✓)	No ( )	
Auto. Wash. Machine	Yes (✓)	No ( )	
Site Suitable	Yes (✓)	No ( )	

Lot Area 200 x 600

Character & Porosity of Soil Yellow Tallow Clay
Percolation Rate _____
Topography Slope to back.
Depth to Water Table _____
Rock or other impervious formations None

2 TANKS



Size of Tank 1000 Gals.
Nitrification Field: 2 Fields -
No. of Lines 2 Lines per Field
Sq. Ft. 1250 Linear Ft. 500
Depth of Stone in Lines 10"
Water Supply: Individual (✓)
Public ( )

Installed by Raymond Adams

IMPROVEMENTS PERMIT BY _____

COMMENTS: Septic tank installed as per request

CERTIFICATE OF COMPLETION BY Glenn Fox Jr. DATE 8/20/74

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold