10912

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Donald Swiregood DATE 2-2-90 PERMIT NO. SH-A-61

PHONE: Business _____ Home _____

LOCATION 70 E TR Knox Rd 1000' on Rt. S. R. No. _____

SUBDIVISION NAME Swiregood MHP LOT NO. 2 SECTION OR BLOCK NO. _____

House ( ) Mobile Home (✓) Business ( ) Other _____

No. Bedrooms 2 No. Bathrooms 2

Garbage Disposal Unit Yes ( ) No (✓)
Auto. Dishwasher Yes ( ) No (✓)
Auto. Wash. Machine Yes (✓) No ( )
Site Suitable Yes (✓) No ( )

Character & Porosity of Soil Clayey
Percolation Rate 1-3
Topography 2 to 6%
Depth to Water Table 10'+
Rock or other impervious formations none


Lot Area 1/2 acre

_____ Basement with Plumbing _____ Basement without Plumbing _____ No Basement

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 2
Sq. Ft. 700 Linear Ft. 300
Depth of Stone in Lines 12"

Water Supply: Individual (✓)
Public ( )



Plot of System

Installed by Wayne Potts

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY P. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY P. C. Moore DATE 2-2-90

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold