PARTMENT OF ENVIRONMENT,
EALTH, & NATURAL RESOURCES
VISION OF ENVIRONMENTAL HEALTH

SHEET___OF___
PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

PLICANT: Bill Bass OWNER:__AGENT:__ PHONE:
DDRESS: APPLICATION DATE:___DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
OCATION OF SITE: E/mwood
ATER SUPPLY: On-Site Well___Comm. Well___Public___Other___EVAL. METHOD: Auger Boring___Pit___Cut___

PROFILE #	.1940 LANDSCP POS. (%)	HORIZON DEPTH (IN.)	.1941 STRUCTURE/TEXTURE	.1941 MINERALOGY/ CONSISTENCE	1942 WETNESS COND.	.1944 RESTRICT HORIZONS	.1948 CLASS OF HORIZ	1943/ 1956 SAPRLT CLASS.	HORIZON LTAR
1	Linear 6%	0 to 6 6 to 48	L GR C SBK	Heavy clay SSAP plastic	PS	PS	PS	N/A	.15
2	Linear 6%	0 to 6 6 to 48	L GR C SBK	Heavy clay plastic	PS	PS	PS	NA	.2
3	Linear 6%	0 to 6 6 to 48	L GR C SBK	Heavy clay plastic	PS	PS	PS	NA	.17
4	Linear 8%	0 to 8 8 to 32 32 to 48	L GR C SBK Clay Sapp		PS	PS	PS	NA	.15
5	Linear 6%	0 to 6 8 to 30 30 to 48	L GR C SBK Clay Sapp		PS	PS	PS	N/A	.17

VAILABLE SPACE (.1945) Y/N SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .17
VALUATED BY: JC Moore OTHER(S) PRESENT:
OMMENTS: