IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System -- G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Staley Anthony DATE 10-30-73 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION Hwy 70 E. To Elmwood T.L. Rt 2303 Across Railroad T.L. [redacted] Beside Elmwood Presbyterian Church. House at End of [redacted] Road

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 3

Garbage Disposal Unit	Yes ( )	No ( )	Percolation Rate	
Auto. Dishwasher	Yes (✓)	No ( )	Topography	Sloping to back
Auto. Wash Machine	Yes (✓)	No ( )	Depth to Water Table	Low
Site Suitable	Yes (✓)	No ( )	Rock or other impervious formations	Rock found toward end of Lines

Character & Porosity of Soil Iredell Clay

Lot Area Acreage



Plot of System

Size of Tank 1500 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 10"

Water Supply: Individual (✓)
Public ( )

Installed by Isenhour Builders

IMPROVEMENTS PERMIT BY _____

COMMENTS: - Poor Soil.

CERTIFICATE OF COMPLETION BY E. A. Stevenson DATE 10-30-73

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold