HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#:
PROPERTY RECORDED:
COUNTY:

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Kenny Watt OWNER: AGENT: PHONE:
ADDRESS: APPLICATION DATE: DATE EVALUATED:
PROPOSED FACILITY:
PROPERTY SIZE:
LOCATION OF SITE:
WATER SUPPLY: On-Site Well Comm. Well Public Other EVAL. METHOD: Auger Boring Pit Cut

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN.)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINERALOGY	
1	linear 2 to 4%	0 to 8	L	GK		.1942 WETNESS CONDITION - some chroma 2 at 36 to 48
		8 to 48	C	ABK	1:1 mixed	.1943/.1956 SAPROLITE - N/A
						.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - marginal
						PROFILE LTAR - .2
2	linear 2 to 4%	0 to 6	L	GK		.1942 WETNESS CONDITION - some chroma two at 36 to 48
		6 to 27	C	SBK	1:1	.1943/.1956 SAPROLITE - N/A
		27 to 48	C	ABK	1:1 mixed	.1944 RESTRICTIVE HORIZON - N/A
						.1945 PROFILE CLASSIFICATION - marginal
						PROFILE LTAR - .25
3						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
4						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -
5						.1942 WETNESS CONDITION -
						.1943/.1956 SAPROLITE -
						.1944 RESTRICTIVE HORIZON -
						.1945 PROFILE CLASSIFICATION -
						PROFILE LTAR -

AVAILABLE SPACE (.1945) SITE CLASSIFICATION (.1945): SITE LONG-TERM ACCEPTANCE RATE:
OTHER FACTORS(.1946) SYSTEM TYPE
EVALUATED BY: OTHER(S) PRESENT:
COMMENTS:

DRAFT

11263