HEALTH, & NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY I.D.#: _____
PROPERTY RECORDED: _____
COUNTY: _____

SOIL/SITE EVALUATION
FOR
ON-SITE WASTEWATER SYSTEM

APPLICANT: Tim Hamby OWNER: __ AGENT: __ PHONE: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: 6-17-94
PROPOSED FACILITY: _____
PROPERTY SIZE: _____
LOCATION OF SITE: Lot 5
WATER SUPPLY: On-Site Well ___ Comm. Well ___ Public ___ Other _____ EVAL. METHOD: Auger Boring ✓ Pit ___ Cut ___

PROFILE #	.1940 LANDSCP POS./ SLOPE %	HORIZON DEPTH (IN)	.1941 (a)(1) TEXTURE	.1941 (a)(2) STRUCTURE	.1941 (a)(3) MINEROLOGY	
1	LINEAR 6%	0 TO 4	L	GR		.1942 WETNESS CONDITION CROMA 2
		4 +	C	ABK	MIXED	.1943/.1956 SAPROLITE N/A
						.1944 RESTRICTIVE HORIZON MOTTLING
						.1948 PROFILE CLASSIFICATION U
						PROFILE LTAR 2.1
2	LINEAR 4%	0 TO 4	L	GR		.1942 WETNESS CONDITION CROMA 4
		4 TO 48	C	ABK	1:1	.1943/.1956 SAPROLITE N/A
						.1944 RESTRICTIVE HORIZON N/A
						.1948 PROFILE CLASSIFICATION PS
						PROFILE LTAR .3
3						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
4						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR
5						.1942 WETNESS CONDITION
						.1943/.1956 SAPROLITE
						.1944 RESTRICTIVE HORIZON
						.1948 PROFILE CLASSIFICATION
						PROFILE LTAR

AVAILABLE SPACE (.1945) Yes SITE CLASSIFICATION (.1948): PS SITE LONG-TERM ACCEPTANCE RATE: .3
OTHER FACTORS(.1946) _____ SYSTEM TYPE Pump To Conv. Lines
EVALUATED BY: C. Moore OTHER(S) PRESENT: Tim Hamby Ernie Runyon
COMMENTS: _____

DRAFT

000549