01876

IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION

(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul Layman DATE 08-05-85 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E, T.R. on New Salem Rd, go 2mi., T.R. on Dixie Dr. (Private Rd), next to last house on left S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit Yes (✓) No ( )

Auto. Dishwasher Yes (✓) No ( )

Auto. Wash. Machine Yes (✓) No ( )

Site Suitable Yes (✓) No ( )

Lot Area 4.88 Acre

Character & Porosity of Soil Class IV - Saprolite


Percolation Rate 04 gal ft²/day

Topography 2-6% Slope

Depth to Water Table 10+

Rock or other impervious formations parent material

✓ Basement with Plumbing ____ Basement without Plumbing ____ No Basement



Size of Tank 1500 Gals.

Nitrification Field:

No. of Lines 4

Sq. Ft. 960 Linear Ft. 320

Depth of Stone in Lines 12"

Water Supply: Individual (✓)

Public ( )

Installed by Paul Freye

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY J. C. Moore

COMMENTS: Modified from permit issued 07-31-84 per J. C. Moore

CERTIFICATE OF COMPLETION BY Jerry L Price DATE 08-05-85

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold