IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System — G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Craig Ballard DATE 7-11-78 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 East TR on 2305 Then TR on 2307 1/2 mi on right S. R. No. _____

SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____


House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes	✓	No		
Auto. Dishwasher	Yes	✓	No		
Auto. Wash. Machine	Yes	✓	No		
Site Suitable	Yes	✓	No		

Lot Area 150 X 200

Character & Porosity of Soil C & B2
Percolation Rate 60 min/inch
Topography 2 to 6% Slope
Depth to Water Table 10'+
Rock or other impervious formations none



Plot of System

Size of Tank 1250 Gals.
Nitrification Field:
No. of Lines 2
Sq. Ft. 750 Linear Ft. 250
Depth of Stone in Lines 16"
Water Supply: Individual (✓)
Public ( )

Installed by Hoke Septic Tank Co.

IMPROVEMENTS PERMIT BY Glenn Fox

COMMENTS: _____

CERTIFICATE OF COMPLETION BY J. C. Moore DATE 7-11-78

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold