IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Paul L Deaton DATE 1-30-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 70E to Elmwood - TL on Sc. #2308 Cross Creek TL on Rd #2307 2½ down on Left new crik S. R No. 2307


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 1½

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Tuscaw Type clay
Auto. Dishwasher	Yes ( )	No (✓)	Percolation Rate	same
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slope To Rt side
Site Suitable	Yes (✓)	No ( )	Depth to Water Table	—
			Rock or other impervious formations	none

Lot Area 1 Acre



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 750 Linear Ft. 300
Depth of Stone in Lines 18"

Water Supply: Individual (✓)
Public ( )

Installed by Harry Rupe

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Troutman DATE 6/30/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold