IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR Hans Heyman DATE 6-18-81 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64E TR on New Salem Ch. Rd Past Ch. 3rd house on L. S. R. No. _____


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other Repair

No. Bedrooms _____ No. Bathrooms _____
Garbage Disposal Unit Yes ( ) No ( )
Auto. Dishwasher Yes ( ) No ( )
Auto. Wash. Machine Yes ( ) No ( )
Site Suitable Yes ( ) No ( )
Lot Area _____

Character & Porosity of Soil Appling Clay
Percolation Rate 2.5 gal / sq
Topography 2 to 6 %
Depth to Water Table 10' +
Rock or other impervious formations none

_____ Basement with Plumbing _____ Basement without Plumbing ✓ No Basement



Plot of System

Size of Tank Existing Gals.
Nitrification Field:
No. of Lines 1
Sq. Ft. 300 Linear Ft. 100
Depth of Stone in Lines 16"
Water Supply: Individual ( )
Public (✓)
16 Ton Pit at end of Existing line
Installed by Robert Hoke

I understand and agree to install septic tank system as specified on this Improvements Permit.

Signed: _____

IMPROVEMENTS PERMIT BY R. C. Moore

COMMENTS: _____

CERTIFICATE OF COMPLETION BY R. C. Moore DATE 6-18-81

EXISTING SYSTEM CHECKED BY: _____ DATE _____

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Permit is VOID if any unauthorized changes are made in installation of system and/or if any false information is supplied in making Improvements Permit.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold