IREDELL COUNTY HEALTH DEPARTMENT

(SEPTIC TANK) IMPROVEMENTS PERMIT AND CERTIFICATE OF COMPLETION
(Ground Absorption Sewage Disposal System – G. S. Chapter 130-Article 13C)

OWNER OR CONTRACTOR John H. Webb DATE 1-16-75 PERMIT NO. _____

PHONE: Business _____ Home _____

LOCATION 64 E. N/W corner of RD # 2314 and 64 E

S. R. No. 2314


SUBDIVISION NAME _____ LOT NO. _____ SECTION OR BLOCK NO. _____

House (✓) Mobile Home ( ) Business ( ) Other _____

No. Bedrooms 3 No. Bathrooms 2

Garbage Disposal Unit	Yes ( )	No (✓)	Character & Porosity of Soil	Red Clay	
Auto. Dishwasher	Yes (✓)	No ( )	Percolation Rate		
Auto. Wash. Machine	Yes (✓)	No ( )	Topography	Slight slope to left side	
Site Suitable	Yes (✓)	No ( )	Depth to Water Table		
			Rock or other impervious formations	None	

Lot Area 1.55



Plot of System

Size of Tank 1000 Gals.

Nitrification Field:
No. of Lines 3
Sq. Ft. 630 Linear Ft. 252
Depth of Stone in Lines 10"

Water Supply: Individual ( )
Public ( )

Installed by Ellis County & Sons

IMPROVEMENTS PERMIT BY _____

COMMENTS: _____

CERTIFICATE OF COMPLETION BY Glenn Todd DATE 1/16/75

CONSTRUCTION MUST COMPLY WITH ALL OTHER APPLICABLE STATE AND LOCAL REGULATIONS.

Health Dept. Copy: White Inspection Dept. Copy: Yellow Sanitarian's Copy: Pink Owner's Copy: Gold