DEPARTMENT OF ENVIRONMENT, HEALTH AND NATURAL RESOURCES
DIVISION OF ENVIRONMENTAL HEALTH
ON-SITE WASTEWATER SECTION

PROPERTY ID #: _____
COUNTY: _____

SF 14

SOIL/SITE EVALUATION *for* ON-SITE WASTEWATER SYSTEM

OWNER: SHELLY ROSENBAUM APPLICANT: _____
ADDRESS: _____ APPLICATION DATE: _____ DATE EVALUATED: _____
PROPOSED FACILITY: _____ PROPOSED DESIGN FLOW (.1949): _____ PROPERTY SIZE: _____
LOCATION OF SITE: SPRING FOREST LOT 14 PROPERTY RECORDED: _____
WATER SUPPLY: ☐ Private ☒ Public ☐ Well ☐ Spring ☐ Other _____
EVALUATION METHOD: ☐ Auger Boring ☒ Pit ☐ Cut
TYPE OF WASTEWATER: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 LANDSCAPE POSITION/ SLOPE %	HORIZON DEPTH (IN.)	SOIL MORPHOLOGY (.1941) STRUCTURE/ TEXTURE	SOIL MORPHOLOGY (.1941) CONSISTENCE/ MINERALOGY	OTHER PROFILE FACTORS .1942 SOIL WETNESS/ COLOR	.1943 SOIL DEPTH	.1956 SAPRO CLASS	.1944 RESTR HORIZ	PROFIL. CLASS & LTAR
1	3% L	0-12	SL, WK, GR	FR NS NP MSP	RELIC mottles @ 12" (10YR 6/8) mix				PS .25
		12-21	C, med, ABK	FI/FI, S, P, SSP					
		21-36	C, med Sap mix, ABK	FR, SS, SP, SSP	36" (10YR 7/2 relic? Stag 12" above)			FRENCH DRAIN	
		36-	Saprolite						
2	3%		SAME AS HOLE 1						PS .25
3	3% L		SAME AS HOLE 1&2						PS .25
4		0-12	SL WK GR	FR NS NP MSP	42" SAP IS USABLE COVERED AT 30 PITS				PS .25
		12-42"	C MD ABK	FR S P SSP					
		42"	SAP/ [redacted]						

DESCRIPTION	INITIAL SYSTEM	REPAIR SYSTEM
Available Space (.1945)	GRN 254, RD	LR PANEL
System Type(s)	4	4
Site LTAR	.25	.25

OTHER FACTORS (.1946): _____
SITE CLASSIFICATION (.1948): PS
EVALUATED BY: L. COOK
OTHER(S) PRESENT: B. JOHNSON